

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7150-1517:106 Page 1 of 1

CATEGORY: Boxes/Pull Stations

LISTEE: Commercial Products Group, *1130 Milepost Dr., Columbus, OH 43228
Contact: Andrew Keller (309) 762-0731

DESIGN: Model MMPS noncoded fire alarm manual pull station. The unit has normally open switch contacts which close when the station is activated. Unit may employ a supplemental local sounder which is NOT intended for use as a required audible signal device. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC, 1A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm manual pull station for use with separately listed compatible fire alarm control panels.

XLf: 7150-0476:127

*Corrected 12-09-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 10, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager